

Testing Equipment

Model: **PVGD**

For the annual test of safety devices (EN 730-1 / ISO 5175)



Safety devices have to be tested every year as detailed below. Without changing of position flow rate comparison checks can be made. Additionally the function of the pressure sensitive valve can be checked. This equipment allows flow rates to be measured as well as testing the function of the pressure sensitive valve.

Equipment:

Connection adaptors for all common threads.
Connection adaptors for DIN- and IBEDA-Couplings

Options:

Test Certificates
Test labels
Connection adaptors for special types (i.e.: asymmetric Inlet- and Outlet stud)

Tests:

Flow comparison between used and new devices.
Function pressure sensitive gas cut-off
Test for gas return.

Preparations for annual test can be simply made on place.

Space required:	50 x 50cm
Gas supply :	Inert gas oder Oil- and grease free compressed air
Working pressure:	3 bis 5 bar
Connection:	G1/4"RH M
Water:	5 cl